

BULLETIN 01-2016

January 2016

**TO: LICENSED GAS CONTRACTORS
LICENSED GAS FITTERS**

SUBJECT: Amendments to THE GAS INSPECTIONS REGULATIONS

Effective December 11, 2015, Cabinet approved two amendments to The Gas Inspection Regulations.

It is important that you are aware of these two amendments.

Maximum Penalty

The maximum penalty that may be imposed for performing gas installation work without a permit (section 13.1) is increased from \$250 to \$2,500 for each item of work performed without a permit.

Standards for Installations

The following documents are adopted (section 16(1)) as standards for the installation of equipment or apparatus under specific circumstances:

CSA-B149.1-15: Natural Gas and Propane Installation Code

CSA-B149.2-15: Propane Storage and Handling Code

CSA-149.6-15: Code for Biogas Generation and Utilization

CSA-B108-14: Compressed Natural Gas Fuelling Stations Installation Code

CSA-B149.3-15: Code for the Field Approval of Fuel-Related Components on Appliances and Equipment


CAN/BNQ/1784-000/2007: Canadian Hydrogen Installation Code

CSA-B149.5-15: Installation Code for Propane Fuel Systems and Containers on Motor Vehicles

As announced in Bulletin 01-2015, the Saskatchewan adoption of the 2015 CSA B149.1, CSA B149.2 and CSA B149.3 gas codes, will be enforced on permits dated on or after **January 1, 2016**.

This information along with the most recent Saskatchewan Codes of Practice of 2015 is available on the SaskPower website (www.saskpower.com) under the Gas Permits link.

Respectfully,



Syed Asif Ali, P. Eng.

Chief Gas Inspector and Director of Gas Inspections