



BLUE HILL WIND GENERATION FACILITY TRANSMISSION LINE PROJECT

June 2019

PROJECT NEED

- **Build a transmission line** to connect the new 176 MW Blue Hill wind generation facility to the grid.
- **Increase total power generation installed capacity** in Saskatchewan by approximately 3.9% to meet growing energy consumption.
- **Increase renewable power generation installed capacity** in Saskatchewan by 16% and further reduce carbon emission.



PROJECT DESCRIPTION

- Build a new 230 kV switching station near the existing Herbert tap;
- Construct approximately 23 km new 230 kV single circuit transmission line to connect the Blue Hill Wind Farm to the new switching station using steel H-Frame structures; and
- The new service line and the new 230 kV Pasqua to Swift Current transmission line will go in and out of the new switching station.




ENVIRONMENTAL ASSESSMENT & APPROVALS

Throughout the planning and construction of the proposed transmission line we will be in on-going communication with the Ministry of Environment (ENV). This will ensure that all regulatory process and procedures are met as required.



ALTERNATIVE CORRIDORS



LEGEND

- EXISTING 23KV TRANSMISSION LINE
- EXISTING 13KV TRANSMISSION LINE
- EXISTING 72KV DISTRIBUTION LINE
- EXISTING OVERHEAD DISTRIBUTION LINE
- EXISTING UNDERGROUND DISTRIBUTION LINE
- EXISTING SPC FIBRE OPTIC CABLE
- EXISTING PIPELINE
- EXISTING R/W/TOWN BOUNDARY LINES
- PROPOSED ROUTE CORRIDOR WEST
- PROPOSED ROUTE CORRIDOR CENTER 1
- PROPOSED ROUTE CORRIDOR CENTER 2
- PROPOSED ROUTE CORRIDOR EAST
- PROPOSED ROUTE CROSSOVERS
- PREFERRED STATION LOCATION
- MINISTRY OF AGRICULTURE LAND
- KNOWN AREA OF BARE SPECIES
- WASTEWATER BED
- POTENTIAL CRASSLAND DP
- FERRUGINOUS HAWK NEST
- CRAB DENESTERS
- MAXIMUM AVOIDANCE BUFFER
- 100M AVOIDANCE BUFFER

NOT FOR CONSTRUCTION

DATE: 14/01/2024	SCALE: 1:5000	PROJECT: 23KV ROUTE CORRIDOR AND STATION LOCATION ALTERNATIVES	CLIENT: SASKPOWER	DATE: 14/01/2024
DESIGNER: [Name]	CHECKER: [Name]	DATE: 14/01/2024	SCALE: 1:5000	PROJECT: 23KV ROUTE CORRIDOR AND STATION LOCATION ALTERNATIVES
DATE: 14/01/2024	SCALE: 1:5000	PROJECT: 23KV ROUTE CORRIDOR AND STATION LOCATION ALTERNATIVES	CLIENT: SASKPOWER	DATE: 14/01/2024
DATE: 14/01/2024	SCALE: 1:5000	PROJECT: 23KV ROUTE CORRIDOR AND STATION LOCATION ALTERNATIVES	CLIENT: SASKPOWER	DATE: 14/01/2024

DISCLAIMER

THIS DRAWING WAS PREPARED FOR SASKPOWER CORPORATION ("SASKPOWER") FOR ITS SPECIFIC INTERNAL PURPOSES ONLY. SASKPOWER DOES NOT WARRANT THAT THE DRAWING IS COMPLETELY ACCURATE OR CORRECT, NOR DOES IT WARRANT THAT THE DRAWING IS REPRESENTATIVE OF THE ACTUAL CONDITIONS OR SITUATION AT THE TIME OF THE DRAWING. SASKPOWER WILL BE RESPONSIBLE FOR ANY DAMAGE OR LIABILITY TO ANY PERSON IN RESPECT OF THE USE OF OR RELIANCE ON THIS DRAWING, IN WHOLE OR IN PART.

POTENTIAL ROUTE ALTERNATIVE COMPARISONS

	WEST	CENTER 1A	CENTER 1B	CENTER 2A	CENTER 2B	EAST A	EAST B
ECONOMIC IMPACTS / ROUTE LENGTH							
Length of transmission line required (km)	22.3	20.1		19.3		17.1	
Cost Estimated from Q4 2018 (T73 structure series = \$529,000/km)	\$11,796,700	\$10,632,900		\$10,209,700		\$9,045,900	
ENVIRONMENTAL IMPACTS							
Permanent Waterbody Crossing	6	8	4	4	4	3	3
Flood Plain, Creek or Coulee Crossing (all spanable)	11	6	6	9	9	3	5
Sensitive Terrain Features (rolling hills)	YES						
Archaeological/Heritage Assessment required	YES						
Impact on Migratory Birds or Important Bird Areas	MINIMAL						
Impact on Rare Species	POTENTIAL	POTENTIAL	POTENTIAL	YES	YES	POTENTIAL	POTENTIAL
Impact on Native Grasslands, Undisturbed Lands	POTENTIAL						
Impact on Designated Lands, Protected Areas, Conservation Easements	NO						
Vegetation Clearing Required	MINIMAL						
AGRICULTURAL IMPACTS							
Land cover / Land use Type	Agricultural/Modified and Native Grassland						
Percent of Route on Cultivated Farmlands (km)	71%	88%	88%	88%	88%	86%	86%
Percent of Route on Modified Grassland (hay/alfalfa) (km)	18%	8%	8%	4%	4%	9%	9%
Percent of Route on Native Grassland (km)	11%	4%	4%	8%	8%	5%	5%
Percent of Route on quarter section or section boundary lines (km)	100%	91%	91%	56%	40%	37%	55%
Percent of Route through quarter sections (not on boundary lines) (km)	0%	9%	9%	44%	60%	63%	45%
Percent of route through hilly terrain (km)	40%	40%	40%	35%	35%	44%	44%
SOCIAL RESIDENTIAL IMPACTS							
Within 2.5km clearance to urban municipality boundaries	NO						
Within 800m clearance to residences / outbuildings	5	4	4	4	5	2	2
Within 60-160m clearance prudent avoidance residential buffer	0	0	0	0	0	0	0
Within 60m minimum clearance buffer	0	0	0	0	0	0	0

STAKEHOLDER FEEDBACK

We received feedback from the majority of impacted landowners. We were asked to:


- Minimize disturbance to the environment and wildlife including leks and raptor stick nests.
- Preserve archaeological resources including teepee rings.
- Build along fence/quarter section line to avoid placing structures diagonally across agricultural land.

We will be doing additional consultation and collecting feedback on the preferred route.




ROUTING CONSIDERATIONS

Selecting a preferred route requires a balanced look at many factors. SaskPower has six considerations that inform the decision-making process for all routing projects:



PREFERRED ROUTE



DISCLAIMER

THIS DRAWING WAS PREPARED FOR SASKATCHEWAN POWER CORPORATION ("SaskPower") FOR ITS SPECIFIC INTERNAL PURPOSES ONLY. SASKPOWER DOES NOT WARRANT THAT THE DRAWING IS COMPLETE, ACCURATE OR CORRECT, NOR DOES IT WARRANT THAT THE DRAWING IS REPRESENTATIVE OF MATTERS DEPICTED THEREIN AS AT THE DATE OF THE REPRESENTATIONS OR WARRANTIES WITH REGARD TO THE ADEQUACY OR SUITABILITY OF THIS DRAWING FOR ANY PURPOSE WHATSOEVER.

SASKPOWER SHALL NOT BE RESPONSIBLE OR LIABLE TO ANY PERSON IN RESPECT OF ANY LOSS, DAMAGE OR INJURY WHETHER DIRECT OR INDIRECT, ARISING OUT OF THE USE OF OR RELIANCE ON THIS DRAWING, IN WHOLE OR IN PART.



PREFERRED
230kV ROUTE CORRIDOR AND
STATION LOCATION
BLUE HILL WIND GENERATION

POTENTIAL ROUTE ALTERNATIVE COMPARISONS

	PREFERRED ROUTE	WEST	CENTER 1A	CENTER 1B	CENTER 2A	CENTER 2B	EAST A	EAST B	AVERAGE
Length of transmission line required (km)	22.7	22.7	21.1		20.3		18.2		20.6
Cost Estimated from Q1 2019 (T73 structure series = \$550,000/km)	\$12,485	\$12,485	\$11,605		\$11,165		\$10,010		\$11,316
Estimated number of heavy angle/deadend structures (one at each station location is included)	8	5	8	8	9	6	5	6	7
Percentage cost premium	20%	20%	14%		10%		LEAST COST OPTION		15%
Permanent Waterbody Crossing	5	6	8	4	4	4	3	3	5
Flood Plain, Creek or Coulee Crossing (all spanable)	3	11	6	6	9	9	3	5	7
Percent of Route on Cultivated Farmlands (km)	78%	71%	88%	88%	88%	88%	86%	86%	85%
Percent of Route on Modified Grassland (hay/alfalfa) (km)	15%	18%	8%	8%	4%	4%	9%	9%	9%
Percent of Route on Native Grassland (km)	7%	11%	4%	4%	8%	8%	5%	5%	6%
Percent of Route on quarter section or section boundary lines (km)	100%	100%	91%	91%	56%	40%	37%	55%	67%
Percent of Route through quarter sections (not boundary lines) (km)	0%	0%	9%	9%	44%	60%	63%	45%	33%
Percent of route through hilly terrain (km)	38%	40%	40%	40%	35%	35%	44%	44%	40%
Within 800m clearance to residences / outbuildings	4	5	4	4	4	5	2	2	4
Total Number of Constraints	6	9	6	5	6	6	4	4	6

PROJECT SCHEDULE

- Consultation Round 1: Q1, 2019
- Consultation Round 2: Q2, 2019
- Engineering / Design Complete: Q3, 2020
- Easement / Permitting Complete: Q3, 2020
- Construction Start: Q4, 2020
- Construction Complete / ISD: Q2, 2021

STRUCTURE TYPE

230kV Single-Circuit
Tubular Steel H-Frame
Tangent Structure
(T70/001)



STRUCTURE TYPE


230kV Single-Circuit Tubular Steel H-Frame Tangent Structure (T70/001)

Pole Spacing: 6.6m (22ft)


Structure Height: 19-27m (62-89ft)

Average Span: ~240m (787ft)

Deflection Structures: Guy-anchored



SIZE COMPARISON OF DISTRIBUTION & TRANSMISSION LINES



230 KV MINIMUM CLEARANCE OF CONDUCTOR

Over Farmland	8.1 meters (26.6 feet)
Over Highways	8.4 meters (27.5 feet)
Over High Load Corridors	11.25 meters (36.9 feet)
Over Railways	9.3 meters (30.5 feet)

TYPICAL 230 KV RIGHT-OF-WAY

H-Frame Standard Width..... 40 meters (131 feet)

ANCHORED STRUCTURES



Heavy Angle Deflection Structure



Medium Angle Deflection Structure

RIGHT-OF-WAY PREPARATION



Drum mulcher clearing a right-of-way for a new transmission line



Cleared right-of-way ready for construction

STRUCTURE SETTING



Auguring pole foundation



Temporary crane pad leveled for structure setting

STRUCTURE SETTING



CONDUCTOR STRINGING




Temporary rider poles



Helicopter Conductor Stringing



Stringing equipment



Conductor on dollies during stringing

OTHER CONSTRUCTION ACTIVITIES



Installing ground rods



Installing sacrificial anodes



Crushed rock backfill



Tension (proof) testing anchors

COMMENTS, QUESTIONS AND SUGGESTIONS

EMAIL: PublicConsultation@saskpower.com

BY PHONE: 1-833-223-3370 (toll free)

IN PERSON: Attend our open house at
the Morse Community Hall, Morse SK to discuss the preferred route
on [June 20, 2019](#)
Anytime between: 12 p.m. and 7 p.m. (come-and-go format)

Everyone is welcome to attend.