

WOLVERINE TO BHP JANSEN NEW TRANSMISSION LINE PROJECT

Preferred Route Selection Update, July 2019



PRESENTATION PURPOSE

- To update you on the project, specifically, how we determined our preferred route.
- To explain our planning and decision-making process, the things we considered, including stakeholder feedback.
- To answer your questions the best we can, and to let you know next steps.



WHY THIS NEW POWER LINE IS NEEDED

- BHP has requested 230 kV service to its proposed Jansen potash mine located about 10 km north of the Village of Jansen.
- A lower voltage line (138 kV) was built in 2010 to provide temporary power to the Jansen site until permanent higher voltage (230 kV) service was needed (initially expected by the end of 2014).
- Revised project timeframes would require the line be in service by late 2021.
- SaskPower is moving forward with the studies and routing work required.



ABOUT THE PROJECT

- 230 kV service will be provided by a new transmission line originating from the Wolverine Switching Station, located in SW34-33-24-W2;
- The single-circuit line will use weathering steel H-Frame structures;
- Total length of the new transmission line will be approximately 44 km;
- BHP would like the line to be in service in late 2021; and
- Estimated project cost is about \$33 million.

BALANCING MANY CONSIDERATIONS



PROJECT SCHEDULE

- Routing Studies
- First Round Stakeholder Consultation
- Preferred Route Studies
- Second Round Stakeholder Consultation
- Transmission Line Design
- Environmental & Geotechnical Field Studies
- Submission to Ministry of Environment
- Acquire Easements
- Construction
- Energization

April -August 2017

November 2017

Nov. 2017 - Sept. 2018

Nov. - Dec. 2018

Jan. 2019- Apr. 2020

April - Oct. 2019


January 2020

May - August 2020


Sept. 2020 - Mar. 2021

Late 2021

PROPOSED CORRIDORS/ROUTES



OUR PREFERRED ROUTE



WHY THIS ROUTE

- At the first round of consultations the two big concerns for landowners were proximity to residences and the impact of transmission structures on farming operations (seeding, spraying, harvest, weeds, etc.).
- This route has no residences within 160 metres, and the least number of residences within ½ mile (800m).
- The majority (72%) of the route is located on legal boundaries, where structures can be placed on the edges of fields rather than in the middle.
- Cross-country portions are kept to a minimum in cultivated land; where they do occur there is flexibility to work with the landowner to reduce structure impacts.

WHY THIS ROUTE

- This route is based on the JANSEN 2A route alternative presented during first-round consultations; JANSEN 2A had the lowest levels of landowner opposition of all the route alternatives.
- Where the route crosses from the JANSEN 2A to JANSEN 1A corridors the crossover portion was already shown in first-round consultations; no new land is impacted.
- The JANSEN 2A route was the shortest, lowest-cost of the route alternatives presented; this route contains all the social and environmental advantages of JANSEN 2A while keeping material and support costs to within 5%.

WHY THIS ROUTE

- Based on fall and spring bird surveys, the JANSEN 1A lake crossing site (used by the Preferred Route) has relatively low level of environmental constraints compared to crossings farther to the south.
- Approaching BHP's mine facilities from the north keeps the service line farther from the mine's tailings piles, which helps mitigate potential reliability issues from salt contamination.
- The location facilitates potential future station construction in the area north and west of Jansen Lake, as per SaskPower's future planning requirements.

PREFERRED STRUCTURE



230kV Single-Circuit
Weathering Steel H-Frame
Tangent Structure

Typical Right of Way: 40m (131 feet)

230 KV MINIMUM CLEARANCE OF CONDUCTOR


Over Farmland 8.1m (26.6 feet)

Over Highways 8.4m (27.6 feet)

High Load Corridors 11.25m (36.9 feet)

Railways 9.3m (30.5 feet)

STRUCTURE TYPE



230kV Single-Circuit
Weathering Steel H-Frame
Tangent Structure
(T73/001)

Bundled Conductor

Pole Spacing: 8.0m (26.2ft)

Structure Height: 19.1 - 27.1m (62.7 – 88.9ft)

Average Span: ~230m (754ft)

Deflection Structures: Guy-anchored



COMMENTS, QUESTIONS AND SUGGESTIONS

EMAIL: publicconsultation@saskpower.com

BY PHONE: 1.866.566.3166